OFFICE OF CIVIL SURGEON,JALANDHAR

NO: Jmal/Tech/Jal/ 20

Date...15/04/2024

TO WHOME IT MAY CONCERN

It is certified that team of Health Inspector inspected the premises of **"Swami Mohan Dass Model School,Behing Verka Milk Plant Jalandhar"** on the basis of the report given by the Team, it is certified that the hygiene condition of the **"Swami Mohan Dass Model School,Behing Verka Milk Plant Jalandhar"** are good at Present.

; water sample report attached

Civil Surgeon, Jalandhar.

Civil Surgeon Jalandhar

Vinod Kumar
HMS

MUNICIPAL CORPORATION JALANDHAR

WATER TESTING LABORATORY
(WATER ANALYSIS REPORT)

REF. NO: -667 REF.DATE:-06 /04/26

Sample provided by:-Swami Mohan Dass Model School,Amritsar bye pass road, Jalandhar

SR.NO	TEST	REQUIRED LIMIT IS10500	SAMPLE
1	COLOUR	5 Hazen	Colorless
2	ODOUR	Unobjectionable	Normal
3	TASTE	Agreeable	normal
4	PH	6.5 – 8.5	6.7
5	DISSOLVED SOLIDS (TDS)	500 ppm	140
6	TOTAL HARDNESS (as $CaCO_3$)	300 mg/l	96
7	ALKALINITY	200 mg/l	72
8	CALCIUM (as Ca++)	75 mg/l	10.4
9	IRON	0.3 mg/l	0.1
10	CHLORIDE	250 mg/l	36
11	SULPHATES	150 mg/l	nil
12	NITRATES	4.5 mg/l	nil
13	FLOURIDE	1.0 mg/l	o.1
14	RESIDUAL CHLORINE	0.2 mg/l	nil
15	TOTAL COLLIFORM COUNT (by MPN method per 100ml)	NIL	nil

REMARKS :- provided water sample found satisfactory as per the applied tests

Jalandhar

DATE:-09 /04/26

Self Attested

Analyst

ANALYST
MUNICIPAL CORPORATION JALANDHAR

Municipal Corporation